

ACTAS Px60 Quick Start Guide Software Update


A software update can be carried out via USB interface directly on the device or via the PC software. Please Ask KoCoS Service for the latest update for your device.

Update via USB interface

1. Tap Service. A software update can be carried out via USB flash drive (FAT/FAT32).




2. Tap Software update then Insert USB flash drive with update (spz file, e.g. DeviceController.Actas P360+-1.05.0000.407.spz). The Software is displayed. Tap the desired update. The software update is carried out automatically. Remove the USB flash drive. The new software is activated.



Update via ACTAS Expert

1. Connect the Device to ACTAS Expert. Then Click Info.



2. Click Update. Tap Service and then Software Update on the test system. Click Update again. Select the update and click Open. Follow the instructions on the test system and in the software.

